



Township of

North Dundas

COUNCIL REPORT

To:	Mayor and Members of Council
From	Angela Rutley
Date of Meeting:	November 8, 2011
Subject:	Water and Sewer report

1. Winchester Cathodic Protection Installation (ISF Funding)


The anode installation on the main line valves in Winchester was completed by the October 31 funding deadline. The asphalt reinstatement however was not satisfactory. The valves were left sticking up out of the asphalt where they could be damaged by snow plows. The contractor rectified the problem, so all work is now complete.

2. Winchester Feedermain and Reservoir

Substantial performance for the reservoir and pumping station portion of the project (phase 2) was awarded on October 31st. The engineers will be preparing a list of deficiencies for the contractor and shortly thereafter, the project team will be meeting to deal with outstanding issues.

3. Fire Hydrant Flushing

Our regular, semi-annual fire hydrant flushing was completed between October 5 and 28 in the Villages of Chesterville and Winchester. During that time, we also co-ordinated with the gentleman performing the tanker shuttle accreditation for the fire department and performed flow tests on the required hydrants.

Prepared by:  _____

Approved by: _____